

## CERTIFICATE OF ANALYSIS

<b>Batch No:</b>	<b>22-07315</b>	<i>Page</i>	<b>Page 1 of 2</b>
<i>Final Report</i>	<b>941878</b>	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	<b>Graymont (Australia) Pty Ltd</b>	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>	<b>Mary Damjanovska</b>	<i>Phone</i>	03 8756 8000
<i>Address:</i>	Locked Bag 969 NORTH SYDNEY NSW 2059 AUSTRALIA	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Brad Snibson Client Manager Brad.Snibson@alsglobal.com
<i>PO No:</i>	<b>775186</b>	<i>Date Sampled:</i>	<b>07-Feb-2022</b>
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	<b>07-Feb-2022</b>
<i>ALS Program Ref:</i>	<b>GRAYMONT</b>	<i>Date Issued:</i>	<b>10-Feb-2022</b>
<i>Program Description:</i>	<b>Miscellaneous Analysis for Graymont</b>		
<i>Client Ref:</i>	<b>Galong Hydrated Lime</b>		

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Cyanide	WK026SF	Scoresby	Fluoride	WK040LL	Scoresby
MS Sol. Metals	WG020A	Scoresby			

### Signatories

Name	Title	Name	Title
<b>Chatura Perera</b>	<b>Team Leader Nutrients</b>	<b>Joseph De Alwis</b>	<b>Analyst</b>
<b>Ricky Singh</b>	<b>Analyst</b>		



Accreditation No. 992  
Accredited for compliance with  
ISO/IEC 17025 - Testing

The report shall not be reproduced,  
except in full and results relate only to  
the items tested.

Samples not collected by ALS and are tested as received.

Soil microbiological testing was commenced within 4 days from the day collected unless otherwise stated.

Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link

Samples are tested within holding time unless otherwise stated.



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
7337494		373063	OTHER	07/02/22

Analysis - Analyte	Sample No. Site Code Units	7337494
Fluoride - Fluoride, as F	mg/L	0.06
Cyanide - Total Cyanide, as CN	mg/L	<0.005
MS Sol. Metals - Aluminium	mg/L	0.4
MS Sol. Metals - Antimony	mg/L	<0.01
MS Sol. Metals - Arsenic	mg/L	<0.01
MS Sol. Metals - Barium	mg/L	<0.01
MS Sol. Metals - Beryllium	mg/L	<0.01
MS Sol. Metals - Boron	mg/L	<0.2
MS Sol. Metals - Cadmium	mg/L	<0.002
MS Sol. Metals - Chromium	mg/L	<0.01
MS Sol. Metals - Cobalt	mg/L	<0.01
MS Sol. Metals - Copper	mg/L	<0.01
MS Sol. Metals - Iron	mg/L	<0.2
MS Sol. Metals - Lead	mg/L	<0.01
MS Sol. Metals - Manganese	mg/L	<0.01
MS Sol. Metals - Mercury	mg/L	<0.001
MS Sol. Metals - Molybdenum	mg/L	<0.01
MS Sol. Metals - Nickel	mg/L	<0.01
MS Sol. Metals - Selenium	mg/L	<0.01
MS Sol. Metals - Silver	mg/L	<0.01
MS Sol. Metals - Strontium	mg/L	0.21
MS Sol. Metals - Thallium	mg/L	<0.01
MS Sol. Metals - Tin	mg/L	<0.01
MS Sol. Metals - Titanium	mg/L	<0.01
MS Sol. Metals - Vanadium	mg/L	<0.01
MS Sol. Metals - Zinc	mg/L	<0.01

A blank space indicates no test performed.